

No.	Hyd #	Location	Make	Model	No. of Outlets		Rotation Open	Number of Turns	Main Size	Main Info	Valve Location	Discharge GPM	Comments
					2 1/2"	4 1/2"							
1	10	Sierra and San Pedro	M	CENT	2		L	16.5	4"	Looped	34' 3" S	640	
2	20	Sierra & San Mateo	M	IMP	2	1	R	17	6"	Looped	1' 10" N	528	
3	30	Laredo & Rio	M	IMP	2	1	R	17	6"	Looped		700	
4	40	1428 Roselawn Rd	M	IMP	2	1	R	17	6"	Looped	1' 6" N	850	
5	50	Roselawn Rd & Palo Alto	M	IMP	2	1	R	17.5	6"	Looped	1' 10" E	1100	
6	60	Laguna & Palo Alto	M	IMP	2	1	L	17	6"	Looped		1100	
7	70	1420 Laguna	M	IMP	2	1	R	17	6"	Looped	20' 8" W	905	
8	80	Laguna & Mesquite Pl	M	IMP	2	1	R	15.5	6"	Looped	1' 6" N	850	
9	90	Placita & El Paso	M	IMP	2		L	16	4"	Looped	20' S	500	
10	100	San Juan & Tampico	M	IMP	2	1	R	16	6"	Looped	2' N	800	
11	110	San Pedro & Tampico	AD	MK 73	2		L	19	4"	Looped	1' 6" E	800	
12	120	1411 Santa Rosa	M	IMP	2	1	R	19	6"	Looped	1' 10" S	650	
13	130	Santa Rosa & San Juan	M	IMP	2	1	R	16.5	6"	Looped	1' 8" S	675	
14	140	El Paso & Santa Rosa	M	IMP	2	1	R	17	6"	Looped	1' 10" S	650	
15	150	San Juan & Monterrey	M	CENT	2		L	18	6"	Looped	1' 10" E	800	
16	160	Roselawn Rd & San Pedro	M	IMP	2	1	R	15	6"	Looped	34' 6" W	800	
17	170	1591 Taos Rd	M	IMP	2		L	16	4"	Looped	27' S	747	
18	180	N Campus Boys Ranch SE	M	CENT	2	1	L	17.5	6"	Looped	12' W	1070	
19	190	N Campus Boys Ranch NE	M	CENT	2	1	L	17.5	6"	Looped	12' 6" S	1070	
20	200	N Campus Boys Ranch NW	M	CENT	2	1	L	17.5	6"	Looped	10' S	1070	
21	210	N Campus Boys Ranch SW	M	CENT	2	1	L	17.5	6"	Looped	2' W	1070	
22	220	Aspen Rd & St. Joseph Church	M	CENT	2	1	L	18	6"	Looped	2' W	528	
23	230	Aspen Rd & Liberty (West)	M	CENT	2	1	L	17.5	6"	Looped	3' E	747	
24	240	Liberty & Bent	K	K-81A	2	1	L	17.5	6"	Looped	9' E	550	
25	250	Aspen Cir & Santa Fe Dr	AD	MK 73	2		L	18.5	4"	Looped	5' N	520	
26	260	1804 Aspen Cir	M	CENT	2		L	18	4"	Looped	9' 7"	800	
27	270	940 Delta St	AVK	27-35	2	0	L	19	4"	Looped	10' W	780	
28	280	Aspen Cir & Aspen Pl	AD	MK 73	2		R	18	4"	Looped	1' W	450	

29	290	Aspen Cir & Frontier (N)	M	IMP	2		R	16	4"	Looped		500	
No.	Hyd #	Location	Make	Model	No. of Outlets		Rotation Open	Number of Turns	Main Size	Main Info	Valve Location	Discharge GPM	Comments
					2 1/2"	4 1/2"							
30	300	Aspen Cir & Autumn (N)	AD	MK 73	2		L	19	4"	Looped	7' N	450	
31	310	Aspen Cir & Autumn (S)	AD	MK 73	2		R	17	4"	Looped		450	
32	320	874 Frontier	AD	MK 73	2		R	19	4"	Looped		500	
33	330	Eagle St & Santa Fe Dr	K	K-81A	2		L	18.5	4"	Looped	6' 6" S	450	
34	340	1115 Holly	M	CENT	2	1	L	18	6"	Looped	7' E	880	
35	350	20th Ln & Santa Fe Dr	M	CENT	2		L	19	4"	Looped	6' E	450	
36	352	2010 Zinno Blvd	AVK	27-80	2	1	L	19	6"	Looped	19' N	1590	
37	354	1254 Zinno Blvd	AVK	27-80	2	1	L	19	6"	Looped	20' W	1590	
38	380	20 1/2 Ln & Iris Rd on Southside	M	CENT	2	1	L	18.5	6"	Looped	16' 6" N	1100	
39	382	20 1/2 Ln & Iris Rd on Northside	AVK	27-80	2	1	L	19	6"	Looped	30' 6" W	1630	
40	384	20 1/4 Ln & Carmela Rd	AVK	27-80	2	1	L	19	6"	Looped	22' 8" N	1590	
41	386	20 1/4 Ln & Iris Rd	AVK	27-80							24' 4" E	1630	
42	360	21st Ln & Hillside Rd	AD	MK 73	2		L	20	4"	Looped	2' 8" E	1030	
43	370	21st Ln & Iris Rd	M	CENT	2	1	L	18.5	6"	Looped	27' N	1950	
44	385	21st Ln & County Farm Rd	M	CENT	2	1	L	18	6"	Looped	17' 9" E	1180	
45	390	20th Ln & County Farm Rd	I	F-5100	2	1	L	12	6"	Looped	2' N	1030	NEEDS REPLACED
46	400	22nd Ln & County Farm Rd	M	CENT	2	1	L	17.5	6"	Looped	6' E	1170	
47	410	2201 Harvey Pl	M	CENT	2		L	19	3"	Looped	12' 6" S	120	
48	420	23rd Ln & County Farm Rd	M	CENT	2	1	L	18	6"	Looped	2' N	1120	
49	430	24 1/2 Ln & County Farm Rd	AD	B-62-B	2	1	R	24	6"	Looped	1' N	1057	
50	440	24 1/2 Ln & Preston Rd	M	IMP	2		R	16	3"	Looped		334	
51	450	25th Ln & County Farm Rd	AD	B-62-B	2	1	R	28	6"	Looped	2' N	1180	
52	460	25 1/2 Ln & County Farm Rd	AD	MK 73	2		L	18.5	4"	Looped	7' 6" W	910	
53	470	Torchey Way & Habana	M	IMP	2		L	15.5	4"	Looped	3' 6" E	910	
54	480	27200 Torchey Way	M	IMP	2		L	16	4"	Looped	3' 6" S	910	
55	490	27251 Preston Rd	M	IMP	2		L	15.5	4"	Looped	2' S	1100	
56	500	1480 Alana	M	IMP	2		L	16.5	4"	Looped	10' 6" E	1000	

57	510	27219 Bronco Dr	M	IMP	2		L	16	4"	Looped	10' 6" S	960	
58	520	1577 Bronco Dr	M	IMP	2		L	16	4"	Looped	10' 6" E	890	
No.	Hyd #	Location	Make	Model	No. of Outlets		Rotation	Number of	Main	Main	Valve	Discharge	Comments
					2 1/2"	4 1/2"	Open	Turns	Size	Info	Location	GPM	
59	530	27th Ln & South Rd	K	K-81A	2	1	L	16	6"	Looped	9' 4" N	1050	
60	540	27567 Brewster Rd	AVK	67	1		L	9	2.5"	Dead End	4' 8" S	120	
61	550	28th Ln & Manning Rd	M	CENT	2		L	19	6"	Looped	10' W	1590	
62	560	2000 Cortner Rd (Tekavich)	M	CENT	2		L	19.5	4"	Looped	5' 6" NE/NW	200	
63	570	23000 St. Charles Rd (Cesar)	K	K-81A	2		L	18	4"	Dead End	41' E		
64	580	1700 25th Ln	E	NO. 2	1		L	14	3"	Dead End	1' E	230	
65	590												
66	600	Anthalia & Lombard	E	NO. 2	1		L	15	3"	Looped	1' 3" E	455	
67	610	Ronzani & Genes	M	STD	1		L	13.5	3"	Looped	3' 5" S	190	
68	620	La Salle Rd & Los Maderos	AD	MK 73	2		L	18.5	4"	Looped	12' N		
69	630	Brushville & Harlow	AD	MK 73	2		L	18.5	4"	Dead End	4' 8" E	500	
70	640	1720 Somerset Ln	M	STD	1		L	14	3"	Dead End		400	
71	642	2275 Chantala	AVK	27-80	2	1	L	19.5	12"	Looped	4' 3" S	1740	
72	644	Chantala Ave & Penny Ln	AVK	27-80	2	1	L	19	12"	Looped	7' S	1710	
73	650	2170 Fallview Dr	M	STD	1		L	14.5	3"	Dead End		400	
74	660	25th Ln & South Rd	K	K-81A	2	1	L	16	6"	Looped		1025	
75	670	Preston Rd & Garland	M	STD	1		L	14.5	3"	Dead End	9' N	420	
76	680	25th Ln & Hanley Rd	AD	MK 73	2		L	18.5	6"	Looped		580	
77	690	Pleasantview Dr & Parkview Dr	M	STD	1		L	13	3"	Looped	3' E	375	
78	700	Supple Cir & Hillside Rd	M	STD	1		L	13	3"	Looped	2' W	375	
79	705	23rd Ln & Hillside Rd	AVK	27-80	2	1	L	18.5	8"	Looped	6' N	1630	
80	710	Hwy 50 E & 23rd Ln SW	M	CENT	2	1	L	19	6"	Looped	4' N	1330	
81	721	Hwy 50 E & 23rd Ln NE	M	CENT	2	1	L	19	6"	Looped	43' 6" W	400	
82	722	24th Ln / Hwy 50	AVK	27-80	2	1	L	17	6"	Looped	6' S	940	
83	723	24 1/2 Ln (Library)	AVK	27-80	2	1	L	18	6"	Looped	16' W	1230	
84	720	Hwy 50 E & Fire Station #1	M	IMP	2		R	21	3"	Dead End	4' S	250	





85	730	Hwy 50 E & 25th Ln (Ad Bldg)	I	F-5100	2	1	L	11	4"	Looped	2' S	1080	NEEDS REPLACED
86	740	25th Ln & Gale Rd	M	CENT	2		L	18	4"	Looped	4' 6" W	710	
87	752	24700 Gale Rd	W	PACER	2		L	15	4"	Looped	4' 8" E	400	
No.	Hyd #	Location	Make	Model	No. of Outlets 2 1/2" 4 1/2"		Rotation Open	Number of Turns	Main Size	Main Info	Valve Location	Discharge GPM	Comments
88	753	24227 Gale Rd	M	CENT	2		L	18	4"	Looped	4' W	840	
89	750	23rd Ln & Gale Rd	AD	MK 73	2		L	18	4"	Looped	2' 6" W	950	
90	760	Oletta Ln (East)	M	CENT	2		L	18.5	4"	Dead End	16' 4" N	370	
91	770	Oletta Ln (West)	M	CENT	2		L	18.5	4"	Dead End	20' 5" S		
92	772	21st Ln & Gale Rd	AVK	27-80	2	1	L	19	6"	Looped	8.5" W	1850	
93	774	21st Ln & Gore Rd	AVK	27-80	2	1	L	19	12"	Looped	13' 5" N	1780	
94	780	Peakview & 21st Ln	AVK	27-80	2	1	L	19	6"	Dead End	9' S	1180	
95	790	2000 Riverview Dr	M	STD	1		L	14	3"	Dead End	1' 6" N	250	
96	792	Riverview Dr / 21st Ln	AVK	27-80	2	1	L	19	6"	Dead End	6' N	1180	
97	794	Clearview Dr / 21st Ln	AVK	27-80	2	1	L	19	6"	Dead End	4' 6" N	1180	
98	800	Climax & Everett Rd	M	CENT	2	1	L	19	6"	Looped	2' E	710	
99	810	Heisler & Everett Rd	M	CENT	2	1	L	19	6"	Looped	2' E	710	
100	820	Turquoise Dr	AD	MK 73	2		L	18	3"	Looped	2' 6" E	375	
101	830	710 23rd Ln	M	CENT	2		L	19	4"	Dead End	7' 6" W	220	
102	840	23rd Ln & Everett Rd	K	K-81A	2	1	L	18	6"	Looped	6' E	750	
103	850	23655 Everett Rd (PV)	K	K-81A	2		L	18	4"	Looped	33" S	520	
104	870	Crimson Ln & Clover Ln	AD	MK 73	2		L	19	4"	Looped	9' 6" S	510	
105	900	N End / Clover Ln	M	CENT	3		L	17.5	4"	Dead End	16' SE		
106	860	Crystal Ln & Shylo Dr	M	STD	2		R	17.5	6"	Looped	8' N	500	
107	880	Manes Subdivision (Shylo Dr)	M	CENT	2		L	18.5	4"	Dead End	10' 3" S	300	
108	890	761 24th Ln	M	CENT	2	1	L	18.5	6"	Looped	15' 6" E	300	
109	910	W End / Cactus Flower Way	AD	MK 73	2		L	18.5	4"	Dead End	14' 8" SE	275	
110	920	W End / Birdsong Dr	AD	MK 73	2		L	19	4"	Dead End	15' 3" E	370	
111	930	Shylo Dr & Open Sky Terrace	AD	MK 73	2		L	18.5	4"	Looped	12' W	370	
112	940	N End / Open Sky Terrace	AD	MK 73	2		L	18.5	4"	Dead End	17' SE	205	

113	943	27th Ln / Everett Rd	AVK	27-80	2	1	L	22	6"	Looped	6' 6" E	530	
114	945	27th Ln / Gale Rd	AVK	27-80	2	1	L	22	6"	Looped	7' E	1710	
115	950	27274 Everett Rd	M	CENT	2		L	18	4"	Looped	31' S	1020	
116	955	28th Ln / Gale Rd	AVK	27-80	2	1	L	19	12"	Looped	6' N	1520	
No.	Hyd #	Location	Make	Model	No. of Outlets		Rotation	Number of	Main	Main	Valve	Discharge	Comments
					2 1/2"	4 1/2"							
117	960	870 27 1/2 Ln	M	CENT	2		L	19	2.5"	Dead End	5' 6" W	500	
118	970	1055 Lynn Dr	M	STD	1		R	15	2.5"	Dead End		260	
119	975	28511 Gale Rd	AVK	27-80	2	1	L	19	12"	Looped	10' N	1510	
120	980	28th Ln & Ingo Pl	M	STD	1		L	13	3"	Looped	3' 6" E	320	
121	990	29th Ln & Gale Rd	M	CENT	2		L	18.5	4"	Looped	6' E	1430	
122	1000	Windrow Dr & 29 1/2 Ln	M	IMP	2		L	16.5	4"	Looped	1' S	340	
123	1010	Gale Rd & 30th Ln	E	NO. 95	1		L	18.5	4"	Looped	7' N	150	
124	1020	1037 29th Ln	M	CENT	2	1	L	18.5	6"	Looped	9' E	850	
125	1030	Misty Meadows Ln & Peaceful Ct	M	CENT	2	1	L	18	6"	Dead End	12' 8" N	1160	
126	1040	29128 Gale Rd	M	CENT	2		L	18.5	4"	Looped	7' N	550	
127	1050	Everett Rd & 29th Ln	M	CENT	2	1	L	17	6"	Looped	7' 9" N	520	
128	1060	29400 Daniel Rd	E	NO. 95	1		L	20.15	4"	Dead End	33' N	157	
129	1070	West End Helger Ct	E	NO. 95	1		L	20	3"	Dead End	15' N	100	
130	1080	Everett Rd & 30th Ln	M	CENT	2		L	18	4"	Looped	10' N	540	
131	1090	Baxter Rd & Everett Rd	M	CENT	2	1	L	18	6"	Looped	5' 6" W	525	
132	1100	Consolidation S/End	M	STD	1		L	13.5	2.5"	Dead End	1' N	230	
133	1110	Ford Rd & Locus Cir	M	IMP	2		L	16	4"	Dead End	1' E	320	
134	1120	1000 Gale Ct	M	CENT	2	1	L	18	4'	Dead End	18' 6" NE	320	
135	1130	31400 Gale Rd	M	CENT	2	1	L	18	4'	Dead End	11' W	320	
136	1140	34th Ln & Ford Rd	M	CENT	2		L	18	2.5"	Dead End	10' N	180	
137	1150	34324 E US Hwy 50	M	CENT	2		L	18	4"	Looped	4' S		
138	1160	County High School (S)	M	STD	2	1	R	16.5	4"	Looped	191' W	450	
139	1170	County High School (N)	M	STD	2	1	L	16.5	6"	Looped	10' 4" N	510	
140	1180	35th Ln & Ford Rd	M	CENT	2	1	L	18	6"	Looped	3' W	510	

141	1185	35th Ln & Everett Rd	M	CENT	2		L	18	6"	Looped	12' W	670	
142	1190	35001 Hidden Mesa West End	M	CENT	2	1	L	18	6"	Dead End	31' E	350	
143	1200	35222 Hidden Mesa	M	CENT	2	1	L	18	6"	Looped	42' 6" N	350	
144	1210	723 35th Ln	M	CENT	2	1	L	18	6"	Dead End	20' N	350	
145	1220	35424 Hidden Mesa	M	CENT	2	1	L	18	6"	Looped	20' 6" N	350	
No.	Hyd #	Location	Make	Model	No. of Outlets		Rotation Open	Number of Turns	Main Size	Main Info	Valve Location	Discharge GPM	Comments
					2 1/2"	4 1/2"							
146	1230	720 Lone Mesa	M	CENT	2	1	L	18	6"	Dead End	46' S	350	
147	1240	729 Sun Mesa	M	CENT	2	1	L	18	6"	Dead End	51' S	350	
148	1250	888 36th Ln	M	CENT	2	1	L	18	4"	Looped	15' W	650	
149	1260	Hwy 50 E & 36 1/2 Ln	E	NO. 95	1		L	20.15	2.5"	Dead End	9' S		
150	1270	37601 Daniel Rd	K	K-81A	2		L	18.5	4"	Looped	24' S	600	
151	1280	36th Ln & Hillside Rd	M	STD	2	1	R	16	6"	Looped		250	
152	1290	Vineland Elementary	M	STD	2		R	17	2.5"	Looped	1' S	450	
153	1300	35th Ln & Iris Rd	W	PACER	2		L	15.5	4"	Looped	13' E	290	
154	1310	35th Ln & Jersey Rd	M	STD	2		R	16.5	4"	Looped	1' S	350	
155	1320	39500 Nicholson Rd	AD	MK 73	2		L	18	4"	Dead End	4' S	100	
156	1330	1127 42nd Ln	AVK	27-80	2	1	L	18	6"	Looped	6' E	378	
157	1335	45800 E US Hwy 50	E	NO.	1		L	21	3"	Dead End	16' 6" N	150	
158	1340	38th Ln & South Rd	M	IMP	2	1	R	18.5	6"	Looped	4' 4" S		
159	1350	36th Ln & South Rd	M	STD	2		R	16.5	4"	Looped	1' S	600	
160	1360	33700 Nicholson Rd	E	NO. 95	1		L	20	4"	Dead End	12' 3" N	360	
161	1370	33rd Ln & South Rd	M	CENT	2		R	19	4"	Looped	6' 4" S	920	
162	1380	32 1/4 Ln & South Rd	AD	MK 73	2		L	18	4"	Looped		980	
163	1390	1322 32nd Ln	M	CENT	2		L	19	2.5"	Dead End	10' W	100	
164	1400	Batzio Subdivision	M	CENT	2	1	L	18		Dead End		600	
165	1402	29850 South Rd (TP #2)	AD	B-62-B	2	1	L	24	6"	Looped	2' 5" W		
166	1410	30th Ln & David Rd	M	STD	2		R	16.5	4"	Looped	1' E	590	
167	1420	29560 County Farm Rd	M	CENT	2	1	L	17	6"	Looped	11' 9" W	1200	
168	1430	Dublin & County Farm Rd	M	IMP	2		R	16	4"	Looped	1' W	525	

169	1440	30400 Elf Way	M	STD	1		L	14	3"	Dead End	10' 4" W	525	
170	1450	Dublin & Iris Rd	M	IMP	2		R	16	4"	Looped	1' W	560	
171	1460	30th Ln & Iris Rd	M	STD	2		R	16.5	4"	Looped	1' E	560	
172	1470	30th Ln & Hillside Rd	M	STD	1		R	15	3"	Looped	9' N	525	
173	1480	1191 Gowa Ln	M	IMP	2		L	16.5	3"	Dead End	3' 3" E	605	
174	1490	1148 Wago Dr	M	IMP	2		L	17	4"	Looped	4' 6"	410	
No.	Hyd #	Location	Make	Model	No. of Outlets		Rotation	Number of	Main	Main	Valve	Discharge	Comments
					2 1/2"	4 1/2"	Open	Turns	Size	Info	Location	GPM	
175	1500	29th Ln & Karen Rd	M	IMP	2		L						
176	1505	29th Ln & Hillside Rd	AD	MK 73	2		L	19	4"	Looped	1' 6" E	1057	
177	1510	29th Ln & Iris Rd	AD	MK 73	2		L	19	4"	Looped	3' 4" E	620	
178	1520	29286 Iris Rd	M	CENT	2		L	18.5	4"	Looped	17' 4" N	1080	
179	1530	29th Ln & County Farm Rd	M	CENT	2	1	L	17	6"	Looped	8' 10" S	1400	
180	1540	29400 Preston Rd	M	IMP	2		L	17	3"	Looped		525	
181	1550	29th Ln & South Rd	M	IMP	2	1	R	18.5	6"	Looped	3' N	1100	
182	1560	1609 Cliffdale	M	IMP	2		L	17	4"	Dead End	1' 4" E	747	
183	1570	1663 Cliffdale	M	IMP	2		L	17.5	4"	Dead End	1' W	747	
184	1580	28433 Pongo Dr	AD	MK 73	2		L	17.5	4"	Looped	13' 8" S	747	
185	1590	28th Ln & Pongo Dr	AD	MK 73	2		L	19	4"	Looped	14' 6" S	747	
186	1600	28th Ln & Spaccamonti Ct	M	CENT	2	1	L	17	6"	Looped	12' 6" W	750	
187	1610	28th Ln & South Rd	K	K-81A	2	1	L	16.5	6"	Looped	7' N	1050	
188	1620	South Rd & Antonio Ct	K	K-81A	2	1	L	17	6"	Dead End	11' 2" W	710	
189	1630	28th Ln & County Farm Rd	M	CENT	2	1	L	17	6"	Looped	12' S	1180	
190	1640	28511 County Farm Rd	M	CENT	2	1	L	17	6"	Looped	9' S	1180	
191	1650	28th Ln & Hillside Rd	M	STD	1		R	16.5	3"	Looped	2' N	475	
192	1660	Hillside Rd/ Woburn Abbey - E	M	IMP	2		L	16.5	4"	Looped	1' W	990	
193	1670	27310 Woburn Abbey	M	IMP	2		L	16	4"	Looped	1" N	925	
194	1680	Hillside Rd / Woburn Abbey - W	M	IMP	2		L	16.5	4"	Looped	1' E	925	
195	1690	1140 27th Ln (Lagrees)	AVK	2780	2	1	L	18.5	6"	Looped	4' N	1070	
196	1700	27th Ln & Iris Rd	M	CENT	2	1	L	18	6"	Looped	4' 2" E	1130	

197	1710	1351 27th Ln	M	CENT	2	1	L	18	6"	Looped	4' 5" E	1210	
198	1720	27th Ln & County Farm Rd	M	CENT	2	1	L	18	6"	Looped	14' 6" E	1220	
199	1730	2114 La Salle Rd	M	IMP	2			16	3"	Dead End	3' N		
200	1740	18th Ln & LaSalle Rd	M	CENT	2	1	L	17.5	6"	Looped	7' 9" S	1380	
201	1750	6 El Pueblo Ranch Way	M	CENT	2	1	R	17	6"	Looped	16' SW	1500	
202	1760	14 El Pueblo Ranch Way	M	CENT	2	1	L	17.5	6"	Looped	7' 8" N	1500	
203	1770	20 El Pueblo Ranch Way	M	CENT	2	1	L	17.5	6"	Looped	7' 5" N	1500	
No.	Hyd #	Location	Make	Model	No. of Outlets		Rotation	Number of	Main	Main	Valve	Discharge	Comments
					2 1/2"	4 1/2"							
204	1780	28 El Pueblo Ranch Way	M	CENT	2	1	R	17	6"	Looped	16' W	1500	
205	1790	1 El Pueblo Ranch Way	M	CENT	2	1	R	17	6"	Looped	12' 8" N	1500	
206	1800	1800 South Rd	M	CENT	2		L	18.5	4"	Looped	4' 6" S	530	
207	1810	1844 County Farm Rd	M	CENT	2	1	L	18.5	6"	Looped	3' N	750	

BLUE		OVER 1,500 GPM
GREEN		1,000 TO 1,500 GPM
ORANGE		500 TO 1000 GPM
RED		LESS THAN 500 GPM

Revised 10/15/19

No.	Location	Make	Model	No. of Outlets		Rotation Open	Number of Turns	Main Size	Valve Location	Discharge GPM	Comments
				2 1/2"	4 1/2"						
1	3222 Avondale Blvd	WAT	PACER	2	1	L	17.5	4	4' 6" W	200	
2	3428 Avondale Blvd	WAT	PACER	2	1	L	17.5	4	1' W	200	
3	Fields Rd & Avondale Blvd	WAT	PACER	2	1	L	17.5	4	6' N	200	
4	45720 Fields Rd	WAT	PACER	2	1	L	17.5	4	5' 9" N	200	
5	44th Ln & Bush Rd	WAT	PACER	2	1	L	14	4	7' 9" E	300	
6	4100 44th Ln	WAT	PACER	2	1	L	18.5	4	2' 2" E	200	
7	44th Ln & Undercliff Rd	WAT	PACER	2	1	L	18	4	5' S	212	
8	40th Ln & Undercliff Rd	WAT	PACER	2	1	L	18	4	9' W	200	
9	40th Ln 1/2 mile N/Undercliff Rd	WAT	PACER	2	1	L	19	4	11' W	188	
10	40th Ln & Bush Rd	WAT	PACER	2	1	L	19	6	4' 9" W	280	
11	3800 40th Ln	WAT	PACER	2	1	L	19	6	3' 6" W	280	
12	2877 40th Ln	WAT	PACER	2	1	L	17	4	4' 9" W	220	
13	41112 Bush Rd	WAT	PACER	2	1	L	19	6	3' S	220	
14	41901 Bush Rd	WAT	PACER	2	1	L	19	6	4' S	220	
15	38594 Bush Rd	WAT	PACER	2	1	L	19	6	5' S	220	
16	Bush Rd & Broadacre Rd	WAT	PACER	2	1	L	15	8	24' 6" N	160	
17	39000 Harbour Rd	WAT	PACER	2	1	L	18.5	4	3' N	220	
18	39990 Harbour Rd	WAT	PACER	2	1	L	12	4		224	
19	40th Ln & Fields Rd	WAT	PACER	2	1	L	19	6	4' N	300	
20											
21											
22											
23											
24											
25											